

**GEOGRAPHIC INFORMATION SYSTEMS
GEOGRAPHIC INFORMATION CENTER
PO BOX 5839
MC ALLEN, TEXAS 78502-5839**

1-800-522-0139

**kh@acnet.net
Copyright 2010**

***** EXAMINATION *****

**MOBILE HOMES, MANUFACTURED HOMES, AND MOBILE HOME
PARKS ACCORDING TO THE 2005 NATIONAL ELECTRICAL CODE**

1. **An appliance that is not easily moved from one place to another**
 - a) in normal use is a fixed appliance
 - b) in normal use is a portable appliance
 - c) in normal use is a stationary appliance
 - d) None of the above

2. **An appliance that is fastened or otherwise secured at a specific location**
 - a) is a fixed appliance
 - b) is a portable appliance
 - c) is a stationary appliance
 - d) None of the above

3. **An appliance that is actually moved is**
 - a) a fixed appliance
 - b) a portable appliance
 - c) a stationary appliance
 - d) None of the above

4. **An area containing a laundry tray, clothes washer, or a clothes dryer is**
 - a) a laundry room
 - b) a laundry area
 - c) a washroom
 - d) All of the above

5. **A contiguous parcel of land that is used for the accommodation**
 - a) of occupied mobile homes is a mobile home center
 - b) of occupied mobile homes is a mobile home facility
 - c) of occupied mobile homes is a mobile home park
 - d) of occupied mobile homes is a mobile home building

6. **A park electrical wiring system contains**
 - a) the electrical wiring
 - b) the electrical equipment
 - c) the luminaires
 - d) All of the above

7. **Mobile homes installed outside a mobile home park**
 - a) in an office park shall not comply with electrical codes
 - b) in a commercial park shall not comply with electrical codes
 - c) in a housing subdivision shall not comply with electrical codes
 - d) shall comply with electrical codes
8. **Electrical codes for a mobile homes intended for connection to a**
 - a) wiring system shall be rated 120/240 volts
 - b) wiring system shall be rated nominal
 - c) wiring system shall be rated 3-wire ac
 - d) Any of the above
9. **The power supply to the mobile home shall consist of**
 - a) a feeder assembly
 - b) not more than one listed 50-ampere mobile home power-supply cord
 - c) a power-supply cord with a securely attached plug cap
 - d) All of the above
10. **A mobile home may be shipped with**
 - a) cords with adapters
 - b) cords with pigtail ends
 - c) extension cords
 - d) None of the above
11. **A suitable clamp shall be provided at the distribution panel board**
 - a) knockout to afford strain relief for the cord
 - b) knockout to increase the voltage
 - c) knockout to increase the amperage
 - d) knockout to increase the length of the cord
12. **The attachment plug cap for a mobile home power supply shall be**
 - a) 3-pole
 - b) 4-wire
 - c) ground type
 - d) All of the above
13. **If a right-angle attachment plug cap for a mobile home power supply shall be**
 - a) oriented so that the grounded member is nearest to the cord
 - b) oriented so that the grounded member is farthest from the cord
 - c) oriented so that the grounded member is wrapped around the cord
 - d) None of the above
14. **The length of a power-supply cord from the end of the cord, including bare**
 - a) leads, to the face of the attachment plug cap shall not be less than 15'
 - b) leads, to the face of the attachment plug cap shall not be less than 18'
 - c) leads, to the face of the attachment plug cap shall not be less than 21'
 - d) leads, to the face of the attachment plug cap shall not be less than 24'

15. **The length of a power-supply cord from the end of the cord, including bare**
 - a) leads, to the face of the attachment plug cap shall not be more than 25'
 - b) leads, to the face of the attachment plug cap shall not be more than 30'
 - c) leads, to the face of the attachment plug cap shall not be more than 36.5'
 - d) leads, to the face of the attachment plug cap shall not be more than 44'
16. **The length of the cord from the face of the attachment plug cap to the point**
 - a) where the cord enters the mobile home shall not be less than 15 feet
 - b) where the cord enters the mobile home shall not be less than 20 feet
 - c) where the cord enters the mobile home shall not be less than 25 feet
 - d) where the cord enters the mobile home shall not be less than 30 feet
17. **The point of entrance of the feeder assembly to the mobile home shall be**
 - a) in the exterior wall
 - b) in a door
 - c) in the bathroom
 - d) in a window
18. **Where the cord passes through walls or floors, it shall be protected by**
 - a) carpeting
 - b) paneling
 - c) means of conduits and bushings
 - d) None of the above
19. **A distribution panel board shall have a clear working space of**
 - a) 12 inches wide and 12 inches in front of the panel board
 - b) 18 inches wide and 18 inches in front of the panel board
 - c) 24 inches wide and 24 inches in front of the panel board
 - d) 30 inches wide and 30 inches in front of the panel board
20. **Where circuit breakers are provided for branch-circuit protection, 240-volt**
 - a) circuits shall be protected by a 2-pole common circuit breaker
 - b) circuits shall be protected by a companion trip circuit breaker
 - c) circuits shall be protected by a handle-tied paired circuit breaker
 - d) Any of the above

**GEOGRAPHIC INFORMATION SYSTEMS
GEOGRAPHIC INFORMATION CENTER
PO BOX 5839
MC ALLEN, TEXAS 78502-5839**

**1-800-522-0139
kh@acnet.net
Copyright 2010**

Name _____

Company _____

Address _____

City _____ State _____ Zip _____

Telephone _____ E-Mail _____

Fax _____ () 24-Hour Fax

() Yes () No If fax and telephone are the same number, shall we call first?

Mail certificates to above address _____ check address _____ envelope address _____

State + Specialty + PE Registration number (i.e. TX EE 12389) _____

State + Professional Land Surveying registration number _____

NC (North Carolina) + Specialty + PE Registration number _____

NC (North Carolina) + Land Surveying Registration Number _____

Professional Affiliations _____

Return this page with your answer sheet and a check or money order For \$100 per course. Use one check for each registrant (in your company) taking one or more courses. We accept company checks (if they are your employer's). We do not accept third-party checks or checks outside of your city of residence. Using third-party checks that do not include your name or company name may invalidate your professional development hours being reviewed by an audit process. Add \$5 for same day processing and priority shipping.

Make checks or money orders payable to Geographic Information Systems.

